



# SERVICE ENTRANCE - OVERHEAD

Single & Three Phase  
100, 200, & 320/400 Amp

11-01-21  
**ER 19-240-N**  
PAGE 1 OF 7

**USE:** Arrangement of service equipment to supply electric energy to an overhead, outdoor, self contained meter installation.


<b>PREVIOUS REVISION</b> 10-01-18	<b>ORIGINATED</b> 03-94	<b>PREVIOUS NUMBER</b> ER 1-160-A(08-01-89) ER 19-730-A (11-15-94) ER 19-740 (03-21-94) ER 19-745 (03-21-94)
--------------------------------------	----------------------------	--

**LATEST REVISION:** Revised drawing to indicate "House knob or clevis provided and installed by the Customer". Added specification for allowed wires and connectors in the meter socket. Updated tables of approved manufacturers with Landis & Gyr / Siemens whom merged.

**REFERENCE:** Indiana Electrical Code / National Electrical Code (IEC/NEC), latest revision  
ER 5-500, 5-550, 7-500, 13-230, 19-290, latest revision  
UL 414, latest revision  
ANSI C12.7, latest revision

### SPECIFICATION:

### TYPICAL OVERHEAD INSTALLATION



## **SERVICE ENTRANCE - OVERHEAD**

Single & Three Phase  
100, 200, & 320/400 Amp



### **1. GENERAL:**

- 1.1 Residential electric and gas meters should both be located on the same side of the home within the front 1/3 to aid meter reading, testing and service, and to aid emergency response in the event of a fire or some other hazardous condition.
- 1.2 This installation is to conform with the Rules and Regulations of any recognized legal inspection service in effect in the community and satisfactory to the Company.
- 1.3 All wiring and equipment for the overhead service entrance shall be owned, installed and maintained by the Customer.
- 1.4 Only the Customer's line and load wires connected to the manufacturer's connection points are allowed in the meter socket. If an additional load tap is required, only manufacturer's tap connector kits are allowed; or, for stud connections, only bolted lug connectors are allowed. No parallel connectors, split-bolt connectors, or insulation piercing connectors are allowed in the meter socket.
- 1.5 The meter installation shall be level and securely mounted to a substantial building, pole or other type mounting structure satisfactory to the Company.
- 1.6 The placement of the house knob or clevis shall be such that it provides proper clearances for the service drop. (see ER 19-290)
- 1.7 Bonding bushings and jumpers shall be used to maintain electrical continuity to service equipment enclosures when the entire concentric knockout is not removed.
- 1.8 The service disconnecting means shall be installed at a readily accessible location nearest the point of entrance of the service entrance conductors.
- 1.9 For grounding refer to ER 7-500 and the latest revision of IEC/NEC.



## SERVICE ENTRANCE - OVERHEAD

Single & Three Phase  
100, 200, & 320/400 Amp

11-01-21  
**ER 19-240-N**  
PAGE 3 OF 7

### 1.10 Conduit & Conductor Recommendations:

Service Size	Service Entrance			
	Conduit (per IEC/NEC)	Service Entrance Conductors (See Notes below)		Grounding (Cu Only)
		Residential 1φ 3W 120/240V	All Other Services	
100 Amps	1 ½ or 2 Inch	#4 Cu	#3 Cu	#8
		#2 Al	#1 Al	
200 Amps	2 Inch	2/0 Cu	3/0 Cu	#4
	2 ½ Inch	4/0 Al	250 KCM Al	
320/400 Amps	3 Inch	400 KCM Cu	500 KCM Cu	1/0
	3 ½ Inch	600 KCM Al	700 KCM Al	

Note: Approved service entrance cable, with weather-proof fittings, may be used between socket and the general service disconnect, where permitted by local authority.

All recommendations for conductor sizes assume a 75°C temperature rating. Larger conductor sizes may be necessary if lower temperature ratings exist. Refer to IEC/NEC 310-16 for proper conductor sizes, in this case.

The following are the recommended insulation types, based on 75°C minimum temperature rating: RH, RHH, RHW, THHW, THW, THWN, THHN, XHHW, USE.

## SERVICE ENTRANCE - OVERHEAD

Single & Three Phase  
100, 200, & 320/400 Amp



- 1.11 All meter sockets shall meet the following specifications, unless otherwise stated below.
- 1.11.1 Meter sockets shall be designed for use with standard detachable type watt-hour meters.
  - 1.11.2 Sockets shall meet the requirements in AEIC, EEI, NEMA Standards for watt-hour meter sockets.
  - 1.11.3 Meter sockets shall have a swing style latch, which will accept padlock or wire style seal.
  - 1.11.4 Meter sockets shall be made of aluminum alloy or galvanized steel.
  - 1.11.5 Meter sockets shall be of the ringless type.
  - 1.11.6 Meter sockets shall be UL listed.
  - 1.11.7 Meter sockets shall be provided with concentric knockouts in the back, sides and bottom.
  - 1.11.8 All by-passes shall be of the manual, horn or lever type, so arranged that the meter socket cannot be sealed with the by-pass on.
  - 1.11.9 Meter sockets shall be provided with a grounding connector for a #6 conductor.
  - 1.11.10 Meter sockets shall be plainly marked with the manufacturer's name, catalog number and electrical ratings.

### 2. **4 JAW - 100 & 200 AMP:**


2.1 Used for the following services:

- 2.1.1 120 volt, 1 phase, 2 wire
- 2.1.2 120/240 volt, 1 phase, 3 wire

### 2.2 **Approved Sockets:**


2.2.1 Any socket which meets the specifications in 1.11 above, and rated for 100 or 200 amps.

Typical wiring for 2 wire installation



100a, 120v, 1ph, 2w

Typical wiring for 3 wire installation



100/200a, 120/240v, 1ph, 3w

**ONLY APPROVED METER SOCKETS AS NOTED IN THE SECTIONS BELOW WILL BE ALLOWED IN NIPSCO SERVICE TERRITORY.**

**3. Optional 4 JAW - 100 & 200 AMP Meter Socket:**


- 3.1.1 Optional Milbank Universal All-In-One Meter Main which has a disconnect and breaker positions built in.
- 3.1.2 Approved for use:

Milbank	Catalog Number
100 Amp	U5168-XTL-100-KK
200 Amp	U5168-XTL-200-KK

**4. 4 JAW - 320/400 AMP:**

- 4.1 Used for the following services:  
120/240 volt, 1 phase, 3 wire
- 4.2 Approved Sockets:
  - 4.2.1 Sockets shall meet all specifications in 1.11 above.
  - 4.2.2 The right line side location of the 320 amp socket box shall be provided with a reduced jaw.
  - 4.2.3 Meter sockets shall be supplied with a label designating "Use 320 Amp Meter Only".
  - 4.2.4 Bypass shall be of the manual, jaw release, lever type.
  - 4.2.5 Approved for use:

Manufacturer	Catalog Number
Landis & Gyr / Siemens	47604-01NI Type HQ-4SUT
Milbank	U1779-RRL
	U5890-X-2/200-BL (See Note 8.1)
	U5059-X-2/200-K3L (See Note 8.1)
Durham	UT-H4309



**320/400a, 120/240v, 1ph, 3w**

**SERVICE ENTRANCE - OVERHEAD**

Single & Three Phase

100, 200, & 320/400 Amp



**5. 5 JAW - 200 AMP:**


5.1 Used for the following services:

- 5.1.1 240 volt, 3 phase, 3 wire (B phase grounded)
- 5.1.2 120/208 volt, 1 phase, 3 wire (contact Local Operating Office for information)

5.2 Approved Sockets

- 5.2.1 Sockets shall meet all specifications in 1.11 above.
- 5.2.2 Sockets shall be provided with a removable ground strap on the fifth jaw.
- 5.2.3 Bypass shall be of the manual, jaw release, lever type.
- 5.2.4 Approved for use:

Manufacturer	Catalog Number
Landis & Gyr / Siemens	40005-01QG
Milbank	U9550-RL
	U5168-XTL-200-KK-5T (See Note 8.2)
Durham	UT-H5203...



**200a, 240v, 3ph, 3w**

**6. 7 JAW - 200 AMP:**


6.1 Used for the following services:

120/208 volt, 3 phase, 4 wire

6.2 Approved Sockets:

- 6.2.1 Sockets shall meet all specifications in 1.11 above.
- 6.2.2 Sockets shall be provided with a strap to connect the neutral to the socket ground jaw.
- 6.2.3 Bypass shall be of the manual, jaw release, lever type.
- 6.2.4 Approved for use:

Manufacturer	Catalog Number
Landis & Gyr / Siemens	40007-01QG
Milbank	U9700-RRL
Durham	UT-H7203...



**200a, 120/208v, 3ph, 4w**


**7. 7 JAW - 320/400 AMP:**

7.1 Used for the following services:  
120/208 volt, 3 phase, 4 wire

7.2 Approved Sockets:

- 7.2.1 Sockets shall meet all specifications in 1.11 above.
- 7.2.2 The right line side location of the 320 amp socket box shall be provided with a reduced jaw.
- 7.2.3 Meter sockets shall be supplied with a label designating "Use 320 Amp Meter Only".
- 7.2.4 Bypass shall be of the manual, jaw release, lever type.
- 7.2.5 Approved for use:

Manufacturer	Catalog Number
Landis & Gyr / Siemens	44707-02
Milbank	U2594-X-K7



**320/400a, 120/208v, 3ph, 4w**

**8. NOTES:**

- 8.1 Optional socket for 120/240 volt, 1 phase, 3 wire, 320 Amp. Has 2-200 Amp main disconnects built in enclosure. Hubs ordered separately.
- 8.2 Optional socket for 120/208 volt, 1 phase, 3 wire 200 Amp. Has main disconnect and breaker positions built in enclosure. Hubs ordered separately.