



Date: November 3, 2023

From: Joe Kutch

Subject: Bailly Generating Station
Notice of SSL

Dept.: Environmental

To: Bailly Generating Station

As of October 4, 2023, the NIPSCO Bailly Generating Station combined CCR unit referred to as Primary 1 and Primary 2, has detections of one or more constituents at statistically significant levels above the groundwater protection standards as prescribed in §257.95. These constituent(s) include:

- Arsenic
- Lithium
- Molybdenum
- Thallium