



Date: March 20, 2020

From: Joe Kutch

Subject: Bailly Generating Station
Notice of SSL

Dept.: Environmental

To: Bailly Generating Station

As of February 19, 2020, the NIPSCO Bailly Generating Station combined CCR unit referred to as Primary Settling Pond #1 and Primary Settling Pond #2 has detections of one or more constituents at statistically significant levels above the groundwater protection standards as prescribed in §257.95. These constituent(s) include:

- Arsenic
- Lithium
- Thallium