

Intercompany Communication

Date: September 28, 2018

From: Joe Kutch

Subject: Bailly Generating Station
Notice of Statistically
Significant Level ("SSL")

Dept.: Environmental

To: Bailly Generating Station

As of September 7, 2018, the NIPSCO Bailly Generating Station CCR unit referred to as Primary Settling Pond #1, has detections of one or more constituents at statistically significant levels above the groundwater protection standards as prescribed in §257.95. These constituent(s) include:

- Thallium