



**Date:** March 20, 2020

**From:** Joe Kutch

**Subject:** Bailly Generating Station  
Notice of SSL

**Dept.:** Environmental

**To:** Bailly Generating Station

As of February 19, 2020, the NIPSCO Bailly Generating Station CCR unit referred to as Secondary Settling Pond #1 has detections of one or more constituents at statistically significant levels above the groundwater protection standards as prescribed in §257.95. These constituent(s) include:

- Cadmium
- Thallium