



**Date:** September 5, 2020

**From:** Joe Kutch

**Subject:** Bailly Generating Station  
Notice of SSL

**Dept.:** Environmental

**To:** Bailly Generating Station

As of August 6, 2020, the NIPSCO Bailly Generating Station CCR unit referred to as Secondary 1, has detections of one or more constituents at statistically significant levels above the groundwater protection standards as prescribed in §257.95. These constituent(s) include:

- Cadmium
- Thallium