

## **Intercompany Communication**

**Date:** August 30, 2023

**From:** Joe Kutch

**Subject:** Michigan City Generating  
Station Notice of SSL

**Dept.:** Environmental

**To:** Michigan City Generating  
Station

As of July 31, 2023, the NIPSCO Michigan City Generating Station CCR unit referred to as the Boiler Slag Pond, has detections of one or more constituents at statistically significant levels above the groundwater protection standards as prescribed in §257.95. These constituent(s) include:

- Arsenic