



Date: February 19, 2021

From: Joe Kutch

Subject: Michigan City Generating
Station Notice of SSL

Dept.: Environmental

To: Michigan City Generating
Station

As of January 20, 2021, the NIPSCO Michigan City Generating Station CCR unit referred to as Primary Settling Pond #2, has detections of one or more constituents at statistically significant levels above the groundwater protection standards as prescribed in §257.95. These constituent(s) include:

- Arsenic
- Thallium