



**Date:** March 9, 2023

**From:** Joe Kutch

**Subject:** R. M. Schahfer Generating  
Station Notice of SSL

**Dept.:** Environmental

**To:** R. M. Schahfer Generating  
Station

As of February 7, 2023, the NIPSCO LLC R. M. Schahfer Generating Station combined CCR unit referred to as the Material Storage Runoff Basin, Metal Cleaning Waste Basin, and Drying Area, has detections of one or more constituents at statistically significant levels above the groundwater protection standards as prescribed in §257.95. These constituent(s) include:

- Cobalt