



Date: August 28, 2025

From: Jeff Loewe

Subject: R. M. Schahfer Generating
Station Notice of SSL

Dept.: Environmental

To: R. M. Schahfer Generating
Station

As of July 29, 2025, the NIPSCO LLC R. M. Schahfer Generating Station CCR unit referred to as the Waste Disposal Unit, has detections of one or more constituents at statistically significant levels above the groundwater protection standards as prescribed in §257.95. These constituent(s) include:

- Arsenic
- Lithium
- Molybdenum