Date:	February 27, 2026	**From:**	Scott Kalemba
Subject:	R. M. Schahfer Generating Station Notice of SSL	**Dept.:**	Environmental
To:	R. M. Schahfer Generating Station		

As of February 17, 2026, the NIPSCO LLC R. M. Schahfer Generating Station CCR unit referred to as the Waste Disposal Unit, has detections of one or more constituents at statistically significant levels above the groundwater protection standards as prescribed in §257.95. These constituent(s) include:

- Arsenic
- Lithium
- Molybdenum