



Date: March 19, 2021

From: Joe Kutch

Subject: R. M. Schahfer Generating
Station Notice of SSL

Dept.: Environmental

To: R. M. Schahfer Generating
Station

As of February 17, 2021, the NIPSCO LLC R. M. Schahfer Generating Station combined CCR unit referred to as the Material Storage Runoff Basin, Metal Cleaning Waste Basin, and Drying Area, has detections of one or more constituents at statistically significant levels above the groundwater protection standards as prescribed in §257.95. These constituent(s) include:

- Cobalt