



**Date:** October 7, 2020

**From:** Joe Kutch

**Subject:** R. M. Schahfer Generating  
Station Notice of SSL

**Dept.:** Environmental

**To:** R. M. Schahfer Generating  
Station

As of September 7, 2020, the NIPSCO LLC R. M. Schahfer Generating Station CCR unit referred to as the Waste Disposal Area Basin, has detections of one or more constituents at statistically significant levels above the groundwater protection standards as prescribed in §257.95. These constituent(s) include:

- Lithium
- Molybdenum