



**Date:** March 19, 2021

**From:** Joe Kutch

**Subject:** R. M. Schahfer Generating  
Station Notice of SSL

**Dept.:** Environmental

**To:** R. M. Schahfer Generating  
Station

As of February 17, 2021, the NIPSCO LLC R. M. Schahfer Generating Station CCR unit referred to as the Waste Disposal Unit, has detections of one or more constituents at statistically significant levels above the groundwater protection standards as prescribed in §257.95. These constituent(s) include:

- Lithium
- Molybdenum