



Date: September 17, 2021

From: Joe Kutch

Subject: R. M. Schahfer Generating
Station Notice of SSL

Dept.: Environmental

To: R. M. Schahfer Generating
Station

As of August 18, 2021, the NIPSCO LLC R. M. Schahfer Generating Station CCR unit referred to as the Waste Disposal Area Basin, has detections of one or more constituents at statistically significant levels above the groundwater protection standards as prescribed in §257.95. These constituent(s) include:

- Lithium
- Molybdenum